

**AMENDMENT NO. 2 NOVEMBER 2011
TO
IS 4020 (PART 12) : 1998 DOOR SHUTTERS —
METHODS OF TESTS**

PART 12 VARYING HUMIDITY TEST

(Third Revision)

(Page 13, clause 2, second sentence) — Substitute the following for the existing:

‘The height, width, thickness as per Part 2 of this standard, general flatness as per Part 3 of this standard, local planeness as per Part 4 of this standard and diagonal of the door shutter shall be measured.’

(Page 13, clause 2, last sentence) — Substitute the following for the existing:

‘The test may be stopped before the end of the period specified, if two successive measurements of general flatness taken at 2 day interval, do not differ by more than 1 percent.’