

**AMENDMENT NO. 2 NOVEMBER 2011  
TO  
IS 4020 (PART 8) : 1998 DOOR SHUTTERS —  
METHODS OF TESTS**

**PART 8 SHOCK RESISTANCE TEST**

*( Third Revision )*

*(Page 8, clause 2.1, first sentence)* — Insert the following at the end:

‘on which door of various sizes can be mounted in a manner similar to their installation in practice. The frame shall be sufficiently rigid so that any deformation that occurs in the frame during testing will have negligible effect on the test results.’

*[Page 8, clause 3.1, fourth line (also see Amendment No. 1)]* — Insert the following between ‘sand’ and ‘until’:

‘of apparent density approx 1 500 kg/m<sup>3</sup> (sand which passes through a sieve of aperture size 2 mm).’