

**AMENDMENT NO. 5 AUGUST 2011
TO**

IS 1293 : 2005 PLUGS AND SOCKET-OUTLETS OF RATED VOLTAGE UP TO AND INCLUDING
250 VOLTS AND RATED CURRENT UP TO 16 AMPERES — SPECIFICATION

(Third Revision)

(Page 35, clause 23.4) — Delete the following para:

‘The voltage drop between each contact and the corresponding conductor, with a test current flowing having a value as prescribed for **21**, shall not exceed 10 mV.’

[Page 78, table, col 2, Subscript 1 for (B) (see also Amendments No. 1 and 2)] — Substitute the following for the existing: .

‘Shall be phased out after 31 December 2011.’

(ET 14)