

AMENDMENT NO. 2 AUGUST 2011
TO
IS 14930 (PART 2) : 2001 CONDUIT SYSTEMS FOR
ELECTRICAL AND COMMUNICATION INSTALLATION*

PART 2 PARTICULAR REQUIREMENTS FOR CONDUIT
SYSTEM BURIED UNDERGROUND

(Page 1, clause 6.1) — Add the following after 6.1:

‘6.1.0 *Resistance to Compression*

6.1.0.1 *Type 450*

6.1.0.2 *Type 750*’

[Page 1, clause 7.1(c)] — Add the following at the end:

‘d) The Classification Code Type 450 or Type 750 according to 6.1.0.1 and 6.1.0.2.’

(Page 2, clauses 8.1 and 8.2, Table 101, last row) — Add the following at the end:

Nominal Size	Outside Diameter mm	Tolerance mm	Minimum Inside Diameter mm
(1)	(2)	(3)	(4)
315	315	+5.7	237

(Page 2, clause 10.2.5, para 1) — Substitute the following for the existing matter:

‘10.2.5 When reaching the deflection of 5 percent, the applied force shall be at least:

- 450 N for conduits with classification declared according to 6.1.0.1, and
- 750 N for conduits with classification declared according to 6.1.0.2.’

*Title changed vide Amendment No. 1 issued in May 2002.