

**DRAFT IN
WIDE CIRCULATION**

DOCUMENT DESPATCH ADVICE

Reference	Date
CED 53:2/T-2	31- 05- 2010

TECHNICAL COMMITTEE:

Cement Matrix Products Sectional Committee, CED 53

ADDRESSED TO:

1. All Members of Civil Engineering Division Council, CEDC
2. All Members of CED 53 and CED 53:2
3. All others interested

Dear Sir (s),

Please find enclosed the following amendment

Doc No.	Title
CED 53(7730)	Draft Amendment No. 3 to IS 783 : 1985 Code of Practice for laying of concrete pipes (First Revision)

Kindly examine the draft amendments and forward your views stating any difficulties which you are likely to experience in your business or profession, if this is finally adopted as National Standard.

Last Date for comments: **31-08-2010** .

Comments if any, may please be made in the format as given overleaf and mailed to the undersigned at the above address.

In case no comments are received or comments received are of editorial nature, you will kindly permit us to presume your approval for the above document as finalized. However, in case of comments of technical in nature are received then it may be finalized either in consultation with the Chairman, Sectional Committee or referred to the Sectional Committee for further necessary action if so desired by the Chairman, Sectional Committee.

The document is also hosted on BIS website **www.bis.org.in**.

Thanking you,

Yours faithfully,

(A.K. Saini)
Scientist 'F' & Head (Civil Engg.)
email : ced@bis.org.in

Encl: as above

FORMAT FOR SENDING COMMENTS ON BIS DOCUMENTS

(Please use A4 size sheet of paper only and type within fields indicated. Comments on each clause/subclause/table/fig etc. be started on a fresh box. Information in column 3 should include reasons for the comments and suggestions for modified working of the clauses when the existing text is found not acceptable. Adherence to this format facilitates Secretariat's work)

NAME OF THE COMMENTATOR/ORGANIZATION: _____

DOC. NUMBER AND TITLE: CED 53(7730)
Draft Amendment No. 3 to IS 783 : 1985
Code of Practice for laying of coincrete pipes
(First Revision)

Sl No. (1)	Clause/Subclause/ Para No. (2)	Comments/suggestions (3)

BUREAU OF INDIAN STANDARDS

DRAFT AMENDMENT FOR COMMENTS ONLY

(Not to be reproduced without the permission of BIS or used as an amendment)

Cement Matrix Products Sectional
Committee, CED 53

Last date for Comments:
31 August 2010

DRAFT AMENDMENT NO. 3
TO
IS 783:1985 CODE OF PRACTICE
FOR LAYING OF CONCRETE PIPES
(First Revision)

(Page 24, clause 15.2) – Insert the following at the end:

'**15.2.1** In certain cases, like in expansive soil or in black cotton soil, pipelines or pipeline foundations may get damaged due to tight gripping bond of the soil with the pipe surface, thereby subjecting it to excessive stresses as the soil shrinks or expands because of its inherent characteristics. In such cases it is recommended that an envelope of required thickness of tamped non-expansive soil like sand or suitable granular material shall be made around the pipeline.'